



P.O. Box 167, Hammonton, NJ 08037
 609-685-9984 Fax: 609-625-2644

September 4, 2012

Dr. Garnell Bailey, Superintendent
 Pleasantville Middle School
 701 Mill Road
 Pleasantville, NJ 08232

RE: Pleasantville High School Child Care

Dear Dr. Bailey,

BACKGROUND:

Coastal Environmental Compliance, LLC (Coastal Environmental) has supervised the mold remediation at the Pleasantville High School being conducted by CORE Mechanical during the month of August, 2012.

FINDINGS:

The following areas have been completed by CORE Mechanical and tested by Coastal Environmental. Below are the final clearance results for the Pleasantville High School Child Care area:

Date	Type Sample	Location	Result (Spores m3)	Fungal Type
8/26/12	Air-o-cell	Ambient	211 253 1,310 42 13 Total Mold Count 1,830	Ascospores Penicillium/Aspergillus Basidiospores Cladosporium Myxomycetes
8/26/12	Air-o-cell	Room A105	41 82 123 Total Mold Count 246	Ascospores Penicillium/Aspergillus Basidiospores
8/26/12	Air-o-cell	Room A105B Total Mold Count	400 400	Cladosporium
8/26/12	Swab	Daycare High Chair Table	--	No fungi detected
8/26/12	Swab	Daycare Crib	--	No fungi detected

AIR SAMPLING RESULTS:

All of the areas tested have passed clearance.

Air sampling in all of the areas tested indicates acceptable levels of airborne fungi, as compared to the outdoors. Concentration and species are comparable to ambient readings.

SURFACE SAMPLING RESULTS:

The surface sample results taken from the Child Care center indicate no fungi detected. All of the areas tested have passed clearance.

RECOMMENDATIONS:

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ The areas are safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville Board of Education with professional services.

Sincerely,
Coastal Environmental Compliance, LLC

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member