



P.O. Box 167, Hammonton, NJ 08037  
609-685-9984 Fax: 609-625-2644

August 31, 2012

Dr. Garnell Bailey, Superintendent  
Pleasantville Middle School  
701 Mill Road  
Pleasantville, NJ 08232

RE: Pleasantville High School Mold Remediation August 2012

Dear Dr. Bailey,

Coastal Environmental Compliance, LLC (Coastal Environmental) had supervised the mold remediation at the Pleasantville High School during July and August, 2012.

All affected areas of the school have been effectively remediated. Visual inspection, Air sampling and swab sampling indicate that all areas have passed clearance.

Air sampling in each of the areas tested indicate acceptable levels of airborne fungi, as compared to the outdoors. The levels are below outdoor levels, and species of fungi are comparable. Random surface sampling of items within the rooms revealed no fungi detected. Laboratory results are attached.

The school is safe for occupancy.

Sincerely,  
**Coastal Environmental Compliance, LLC**

*Marylee K. Morinelli-Space*

Marylee K. Morinelli- Space  
President/Member