



P.O. Box 167, Hammonton, NJ 08037
609-685-9984 Fax: 609-625-2644

August 25, 2013

Mr. William Marsh
Pleasantville School District
Pleasantville Middle School
801 Mill Road
Pleasantville, NJ 08232

RE: Pleasantville Middle School

Dear Mr. Marsh,

BACKGROUND:

Coastal Environmental Compliance, LLC (Coastal Environmental) has supervised the mold remediation at the Pleasantville Middle School being conducted by ServPro Egg Harbor Twp., during the month of August, 2013.

FINDINGS:

The following areas have been completed by ServPro, and tested by Coastal Environmental:

Rooms A-102, A-103, A105A&B, A-106, A-107, A-122, B-101, B-103, C-101, C-102, C-103, C-104, C105A&B, C-106, C-107, C-108, C-121, C-122, B-202, B-204, B-205, C-206, B-210, C-202, C-204, C-222, C-212, E-113, Nurse, Library, Main Office Suite

AIR SAMPLING RESULTS:

All of the areas tested have passed clearance.

Air sampling in all of the areas tested indicates acceptable levels of airborne fungi, as compared to the outdoors. Concentration and species are comparable to ambient readings.

SURFACE SAMPLING RESULTS:

The surface sample results taken from all of the work areas indicate no fungi detected. All of the areas tested have passed clearance.

RECOMMENDATIONS:

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ The areas are safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville Board of Education with professional services.

Sincerely,
Coastal Environmental Compliance, LLC

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member