



**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2014**

Prepared for:

Pleasantville School District
Pleasantville, New Jersey

Prepared by:

Coastal Environmental Compliance, LLC
P.O. Box 167
Hammonton, NJ 08037
P: 609-820-9312 * F: 609-561-6197

September 6, 2014

**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2014**

Prepared By:

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member

The information contained in this document is confidential and intended for the exclusive use of the Client named on the cover page, and only with respect to the Facility which is the subject of this document. Any other disclosure, use, copying, distribution or taking of any action in reliance on the contents of this document is prohibited. Coastal Environmental Compliance, LLC. shall not be liable to any person for use of this document, and any information contained therein, except as expressly authorized by Coastal Environmental Compliance, LLC. Coastal Environmental Compliance, LLC. shall not be liable to the Client or any person or entity, in the event the Client fails to respond to the findings or implement the recommendations provided within this document.

The information herein is provided based on current technology and guidelines established by professional and governmental organizations involved in environmental issues. It is based on physical and regulatory conditions in existence at the time the Facility was visited for the purpose of preparing this document, or at the time of document delivery to the Client, if no Facility was visited for the purpose of preparing this document.

©2014 Coastal Environmental Compliance, LLC. All Rights Reserved.

**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2014**

Table of Contents

1.0 BACKGROUND	4
2.0 APPROACH	4
3.0 FINDINGS & OBSERVATIONS	5
4.0 RECOMMENDATIONS	6
APPENDIX A – Lab Results	

1.0 BACKGROUND

Coastal Environmental Compliance, LLC (Coastal Environmental) was contacted to conduct clearance inspection and testing at the Pleasantville High and Middle Schools, Leeds Avenue School, Washington Avenue School, North Main and South Main Street Schools, Pleasantville, New Jersey. This inspection was conducted following a mold remediation at each of the schools.

This report details the complete inspection and testing results for the schools.

2.0 APPROACH

2.1 SAMPLING METHODOLOGY

Microbiological air sampling was conducted throughout the properties, and one outdoor location using a low flow pump and air-o-cell cassettes (spore traps). Samples were evaluated for total count and identification of fungi, and other particulates.

ProLab, Inc., Weston, Florida performed the analysis, according to guidelines proposed by the USEPA, and the AIHA Field Guide For The Determination Of Biological Contaminants In Environmental Samples, 1996.

3.0 FINDINGS & OBSERVATIONS

3.1 VISUAL INSPECTION

A visual inspection of the buildings was conducted on August 26-29, 2014. The concerns and visual observations are as follows:

- ✚ All areas are free of visible mold.
- ✚ No areas of concern found in the schools found.

3.2 SAMPLE RESULTS

3.2.1 Microbiological Testing

Microbiological clearance testing was conducted throughout the buildings on August 26-29, 2014. The results are as follows: Please see attached laboratory results.

SCHOOL	ROOM LOCATIONS	RESULTS
High School	JROTC Break Rm., B103, B109, Cafeteria, D110 Offices: 1 st Office on Right, 1 st Office on Left, C205, A204, A207, Nurse, TV Studio, Child Care Room, Control Room above Stage, Auditorium	Passed Clearance
Middle School	C121, A108, A201, C222, B204	Passed Clearance
Leeds Avenue School	Nurse, Principal's Office, Offices in Library, 108, 128, 134, Kwing Rm. 2 & 3, 304, 318, Library	Passed Clearance
Washington Avenue School	103, 106B, 121, 122, Guidance, Principal's Office	Passed Clearance
North Main Street School	107, 118, 122, Library	Passed Clearance
South Main Street School	101, 102, 108, 109, 110, 111, 122, Cafeteria, B112, B129	Passed Clearance

4.0 RECOMMENDATIONS

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ All areas as safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville School District with professional services.

APPENDIX A

Laboratory Results