



P.O. Box 167, Hammonton, NJ 08037  
609-685-9984 Fax: 609-625-2644

August 25, 2013

Mr. William Marsh  
Pleasantville School District  
Pleasantville Middle School  
801 Mill Road  
Pleasantville, NJ 08232

RE: Pleasantville High School

Dear Mr. Marsh,

**BACKGROUND:**

Coastal Environmental Compliance, LLC (Coastal Environmental) has supervised the mold remediation at the Pleasantville High School being conducted by ServPro Egg Harbor Twp., during the month of August, 2013.

**FINDINGS:**

The following areas have been completed by ServPro, and tested by Coastal Environmental:

Rooms A-101, A-102, A-103, B-104, A-105B, A-107, A-108, A-110, A-122, B-102, B-103, B-105, B-106, B-107, B-108, B-109, B-111, B-112, C-101, C-102, C-103, C-104, C-105, C-109, C-201, C-202, C-204, C-206, D-102, Nurse, JROTC and attached Offices, Guidance, Daycare, Auditorium, Dressing Rooms, Trailer 1
---

**AIR SAMPLING RESULTS:**

All of the areas tested have passed clearance.

Air sampling in all of the areas tested indicates acceptable levels of airborne fungi, as compared to the outdoors. Concentration and species are comparable to ambient readings.

**SURFACE SAMPLING RESULTS:**

The surface sample results taken from all of the work areas indicate no fungi detected. All of the areas tested have passed clearance.

**RECOMMENDATIONS:**

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ The areas are safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville Board of Education with professional services.

Sincerely,  
**Coastal Environmental Compliance, LLC**

*Marylee K. Morinelli-Space*

Marylee K. Morinelli-Space  
President/Member