



P.O. Box 167, Hammonton, NJ 08037
609-685-9984 Fax: 609-625-2644

September 4, 2013

Mr. William Marsh
Pleasantville School District
Pleasantville Middle School
801 Mill Road
Pleasantville, NJ 08232

RE: Leeds Avenue School

Dear Mr. Marsh,

BACKGROUND:

Coastal Environmental Compliance, LLC (Coastal Environmental) has supervised the mold clean up at the Leeds Avenue School conducted by district staff, during the month of August, 2013. Only the Kindergarten wing had issues that required attention. The remainder of the school was mold free.

FINDINGS:

The following areas have been completed by district staff, and tested by Coastal Environmental:

Rooms 401 &402

AIR SAMPLING RESULTS:

Room 401 has passed clearance. Air sampling in Room 401 of the areas tested indicates acceptable levels of airborne fungi, as compared to the outdoors. Concentration and species are comparable to ambient readings.

The results of Room 402 will be received on Thursday, September 5, 2013.

RECOMMENDATIONS:

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ The School is safe for occupancy, with the exception of Room 402, which will be sent as soon as results are received.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville Board of Education with professional services.

Sincerely,
Coastal Environmental Compliance, LLC

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member