



P.O. Box 167, Hammonton, NJ 08037
609-685-9984 Fax: 609-625-2644

September 3, 2013

Mr. William Marsh
Pleasantville School District
Pleasantville Middle School
801 Mill Road
Pleasantville, NJ 08232

RE: Pleasantville Indoor Air Quality Clearance Letter - Washington Avenue School

Dear Mr. Marsh,

Coastal Environmental Compliance, LLC (Coastal Environmental) has supervised the mold remediation at the Pleasantville Washington Avenue School being conducted by District Staff during the month of August, 2013.

All of the affected areas have been air tested, and all indicate acceptable levels of airborne fungi, as compared to the outdoors. Concentration and species are comparable to ambient readings.

The surface sample results taken from all of the work areas indicate no fungi detected. All of the areas tested have passed clearance.

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ The areas are safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville Board of Education with professional services.

A full report will be provided to the District along with the laboratory test results.

Sincerely,
Coastal Environmental Compliance, LLC

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member